

12/Aug/2005

BG 64 kHz

23:22 #9646 pedestals
 #9647 LED gain calib. w/o BG
 #9648 LED gain calib. with BG BG rate 64 kHz
 # HV error @ 0-1-9 ⇒ Junk
 #9649 same as #9648
 HV error @ 0-0-9 ⇒ Junk
 #9650 same as #9648
 HV error @ 0-1-9, 0-7-6 ⇒ Junk
 #9651 same as #9648
 #9652 BG LED monitor · 200Hz
 · Qsum ~ 1.8 x 10⁵

23:55 #9653 α ⇒ Junk

Connection broken to LP framework

13/Aug/2005

00:00 #9654 α

00:04 Circulation pump off

8:15 circulation pump started

HV error @ 0-0-9


13/Aug/2005

15:00 During rate dependence test,
 almost all HV is set to 800V,
~~and~~ there were ~50 PMTs which maximum current
 is less than 5 μA. We want to test 1 μA ~ 10 μA region.
 So, for ~50 PMTs, HV values to 1000V is set.

PMTs badlist

T9
T2
L8
R8

ADC#



Aug 12, 05 23:04

T9	0	257.489	4.05545
T2	5	235.18	3.70409
L8	8	277.616	4.37245
R8	10	223.841	3.52555
T3	12	245.916	3.87318
L3	13	231.695	3.6492
F13	23	244.809	3.85574
F10	24	282.653	4.45178
F25	25	175.516	2.76438
F7	27	223.263	3.51639
F20	29	118.48	1.86606
F14	31	224.245	3.53186
T11	32	209.561	3.30059
L11	33	229.059	3.60768
R11	35	312.244	4.91784
T0	37	259.895	4.09335
R0	38	199.89	3.14827
BT0	39	252.542	3.97754
L6	40	172.133	2.71109
R6	42	155.645	2.45141
L5	45	128.499	2.02386
T13	77	261.969	4.12601
T14	81	216.578	3.4111
T17	84	266.791	4.20196
T16	88	216.827	3.41503
T15	92	175.89	2.77027
BT15	94	313.387	4.93585
F4	98	168.518	2.65416
F5	100	186.792	2.94197
F34	112	314.033	4.94602
F0	115	206.807	3.25721
BT25	159	313.749	4.94155
T18	173	176.667	2.78251
R30	178	188.164	2.96358
R29	207	247.914	3.90465
T34	208	227.841	3.5885
R40	212	308.066	4.85204
BK32	220	148.932	2.34568
T36	225	251.107	3.95494
R36	226	172.01	2.70916
T39	232	220.51	3.47303
BK24	243	94.6174	1.49022
BK28	253	166.75	2.62631
BK23	255	207.325	3.26537
BK8	256	198.142	3.12074
BK0	263	212.267	3.34321
BK22	265	306.029	4.81996
BK7	268	210.879	3.32134
BK4	271	221.263	3.48489

1.7
1.5
1.1
0.8
1.3
0.9
1.9
0.7
1.0
1.5
0.4
0.5
2.0
1.2

1100V ←
(3# ADC)
700

1100V ←
(700 ADC)

1100V ←
1100V ←
-500

calculated current (μA)

this will be 8 times larger
when HV is 1000V.

15:20

HV # 0-5-7, # 0-7-11, # 0-13-3
 ↓
 +13
 +950V

13/Aug, /2005

15:30 #9655 pedestal
#9656 LED #1, #5, #8
Background monitor
(LED #2, #6 disconnected)
→ trigger setting was wrong. Junk.

15:40 #9657 LED #1, #5, #8.
Background LED monitor.

L6, F4, BK24, BK28 were low ADC counts.
→ 1100V

15:50 #9658 LED #1, #5, #8.
Background LED monitor

T13 → 1000V → 950V
several times hv error.

#9660 LED #1, #5, #8
BG LED mon. ~ 10K events.

LED BG 1kHz

16:11 #9661 const LED run without B.G.
LED(#2, #6) = (60, 71)
Qsum ~ 95000

16:13 #9662 const LED run with 1kHz LED B.G.

16:18 #9664 pedestal with B.G.

LED BG 2kHz

16:20 #9665 BG monitor run
LED (#1, #5, #8)
Ⓡ Ⓛ Ⓣ

16:24 #9666 pedestal w/o B.G.

16:26 #9667 LED (#2, #6) const w/o B.G. ~ 200000 Qsum

16:30 #9668 LED (#2, #6) const with 2kHz B.G.

HV error #0-15-2
BK32

16:34 #9669 pedestal with 2kHz B.G.

16:36 #9670 BG monitor run ... forgot to disconnect #2, #6.
#9671 BG monitor run. junk.

LED BG 4kHz

#96723 pedestal w/o BG
16:42 #96745 LED const (#2, #6) w/o BG
LED const (#2, #6) with 4kHz BG

HV error #0-0-11
#0-4-7

We changed HV 800V → 1000V, but these bad channels
the gain was not small. We should not go up HV value,
but LED setting.

Now all bad channels set to 800V
other PMTs HV off.

13 / Aug / 2005

17:25 #9676 pedestal w/o B.G.

17:45 #9677 LED (#1, #5, #8) (71, 73, 83)
B.G. monitor (76, 77, 87)

2 sum.
~ 80000

ADC #40, L6 → 800V → ~~1100~~ 1100V (low gain)

#98, F4 → 800V → 1100V (")

#243 BK24 - 800V → 1100V (")

#253 BK28 800V → 1100V (")

1 kHz LED run

17:50 #9678 const LED (#2, #6) w/o B.G. ^{2 sum} ~ 12000

17:52 #9679 " With 1 kHz B.G. ~ 12000

17:54 #9680 pedestal with B.G.

17:56 #9681 LED B.G. monitor

2 kHz LED run

17:58 #9682 pedestal w/o B.G.

18:00 #9683 LED const w/o B.G.

18:02 #9684 LED const with 2 kHz B.G.

18:05 #9685 pedestal with "

18:07 #9686 LED B.G. monitor

13 / Aug / 2005

4 kHz LED run

18:10 #9687 pedestal w/o B.G.

18:11 #9688 LED const w/o B.G.

18:13 #9689 LED const with 4 kHz B.G.

18:15 #9690 pedestal with B.G.

18:17 #9691 LED B.G. monitor

8 kHz LED run

18:19 #9692 pedestal w/o B.G.

18:21 #9693 LED const w/o B.G.

18:23 #9694 LED const with 8 kHz

18:25 #9695 pedestal with B.G.

18:27 #9696 LED B.G. monitor

16 kHz LED run

18:29 #9697 pedestal w/o B.G.

18:30 #9698 LED const w/o B.G.

18:33 #9699 " with 16 kHz

18:35 #9700 pedestal with " B.G.

18:38 #9701 LED B.G. monitor

13/Aug/2005

24 kHz LED run

18:40 #9702 pedestal w/o B.G.
 18:41 #9703 LED const w/o B.G.
 18:43 #9704 LED const with B.G. 24 kHz
 18:46 #9705 pedestal with B.G.

HV #0-3-2 error

18:48 #9706 LED B.G. monitor

32 kHz LED run

18:50 #9707 pedestal w/o B.G.
 18:52 #9708 LED const w/o B.G.
 18:55 #9709 LED const with 32 kHz
 18:57 #9711 pedestal with B.G.

18:59 #9712 LED B.G. monitor

48 kHz LED run

19:02 #9713 pedestal w/o B.G.
 19:04 #9714 LED w/o B.G.
 19:06 #9715 LED const with 48 kHz B.G.
 19:08 #9716 pedestal with B.G.

19:10 #9717 LED B.G. monitor

13/08/2005

64 kHz LED run

19:15 #9718 pedestal w/o B.G.
 19:17 #9720 LED const w/o B.G.
 19:37 #9721 LED const w/ B.G.

} megonln 01
 kernel Panic.
 restarted.

HT error #0-4-1.

19:40 #9722 pedestal with B.G.

19:43 #9724 pedestal no B.G.
 #9725 LED (#2, #6)
 with (59, 68, step 1) as first step.

Rate dependence test finished //

HT setting to 10^6 gain, by using "050808-5.hv"
 and manually for CAEN HV by using "050805-7.hv"

20:00 #9726 pedestal @ 10^6 gain
 20:05 #9727 LED (#2, #6) → (59, 68, step 1)
 20:10 #9728 α
 20:15 #9729 α
 20:25 #9730 CR.

20:30 circulation stop

20:53 0.110 MPa Inner pressure.

We will test to stop refrigerator operation and see how long the inner pressure go up when PMT HTU is "ON".

- compressor stop.
(rotary valve power should be turned down manually)
- heater around refrigerator off.

~~23:48 #9732 CR~~

23:57 HV01 Down.
→ automatically recover

14 Aug. / 2005

00:24 #9732 CR ⇒ 9:38 (Aug. 14) stopped

0

00:30 0.123 MPa Inner pressure

- compressor ON
rotary valve power ON
- heater ON

14/Aug/2005

9:00 Xe recovery tank weight. 513.08 kg

(Now, this is empty.)

→ 250L tank cooling start

9:45 #9733 pedestal

#9734 LED

#9735 alpha

#9736 alpha

10:00 All hv off for xenon recovering

400L tank
300L left
LN2

Waveform Data Taking with Oscilloscope

- Using oscilloscope (TDS 5104), we take waveform of Xe signal (Cosmic ray or environmental gamma).
1 channel
- Self-trigger → Threshold -1.0V
- PMT F10 (#15) - ADC 24 - splitter - 0-3-1
- Use LabVIEW VI for data acquisition (multiGetWaveform.vi)

c: \Document and Settings \muegamma \waveform

waveform.dat ⇒ before splitter ~3000 events

waveform2.dat ⇒ after splitter 992 events

waveform3.dat ⇒ input of ADC (after Delay cable) 1115 events

Threshold -500mV

0-80 events vertical ~~div~~ 1V

681-1115 events " 500mV

horizontal window 40ns x 10 div
record length 2000 samples

15:45 Xe recovery started.

- Refrigerator OFF
 - Minco heater ON
 - HV OFF
- OV filled with 0.5 atm N₂.

16:00 400 l tank LN₂ filled.

• Notice

We need to take gas & data.

When SM bottom sensor ~~is~~ becomes over the xenon liquid level or the value of level meter becomes 0, (lower one),

Xenon recovery should be stopped and please change the operation mode to refrigerator pressure control, (0.17 MPa) and stop the minco heater.

- Close the valve in front of 250 l tank
- stop the minco heater
- start refrigerator pressure control. and don't forget to turn on the rotary valve power.

- take & data. (HV should be turned on)
- after taking & data, don't forget to turn off HV.
- Inner volume pressure ~~is~~ goes down (~ 0.1 MPa) then evacuate outer vessel, and heater control bottom should be changed to temperature control.

xenon recovery restart. →

- when xenon recovery finished, IV, OV will be filled with Nitrogen. ~ 1 atm.

21:00 400 l LN₂ tank filled.

15 / Aug / 2005

4:43 SM bot: -84.7°C
lower level meter: 75%

- The temperature of 'SM bot' indicates temperature of GXe. 'SM bot' must be either 'SM mid' or 'SM top'. and gradually increases.

8:00 400 l LN₂ tank empty.

9:20 400 l LN₂ tank filled

17:17 To read out flow meter, ~~the~~ terminal connections were swapped @ yellow terminal.
SCS 520 35 ↔ 37

15:50 Xe recovering paused. { lower level meter ~ 0.1
Inner pressure ~ 0.148 MPa.

- Stop minco heater.
- compressor ON (rotary valve also ON)
- Refrigerator control ON (pressure setting ~ 0.148 MPa)
- Close the valve of 250 l tank.
- HV ON by the file, "050808-5.hv" (10⁶ gain setting).

16:00

Pressure setting 0.148 → 0.153 MPa

HV Error. 0-7-10 (L18)

0-12-10 (L37)

• temperature. SM bottom HL up HL down Cold Head Minco
-75.02 -94.09 -93.72 -92.74 -103.05

15/Aug/2005

gas α data

16:15 #9737 #9738 pedestal @ 10^6 gas xenon.

16:26 #9739 LED @ 10^6

(#2, #6) = (59, 68, step 1)

16:36 #9740 α @ 10^6 ~ 30K. 0.154 MPa.

HV error #0-0-9 (BT2)

16:44 #9741 α @ 10^6 0.154 MPa

16:51 #9742 α @ 10^6 0.155 MPa

16:57 #9743 α @ 10^6 0.155 MPa


17:07 #9744 α @ 10^6 0.155 MPa

17:12 #9745 α @ 10^6 0.155 MPa

17:26 #9746 α @ 10^6 0.156 MPa.

finish data taking

//



18:00 Xenon recovery restarted.

20:20 400Q LN2 tank filled.

21:22 Pressure of LP. 0.1 MPa → START evacuating
Outer Insulation Layer.

21:54 Xe Recovery to half gallon tank START

22:10 250Q Xe tank valve closed.

0.011 MPa } Xe will be transferred to half gallon bottle.
-90°C

Minco heater control → temperature mode → OFF.

23:50 0.004 MPa } → Xe Recovery Finished!
-87.0 (HL TOP)
-84.01 (HL LOW)

16/8/2005

9:15 N2 into IV ~ 1atm
OV ~ 0.8atm

File Backup

• Source code, Etc... lafs/psi.ch/project/meg/2005_2

• Root files) ftp://meg@archivftp/~ / 2005_2
Midas files)